

Skylonda Mutual Water Company

127 Blakewood Way, Woodside, California 94062

Telephone 650 851-0154.

Email: skylondawater@hotmail.com

August 24, 2016

IMPORTANT NOTIFICATION

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.

Dear Customer of Skylonda Mutual Water Company,

The Skylonda Mutual Water Company has been cited by the State Water Resources Control Board Division of Drinking Water for distributing water containing quantities of total trihalomethanes (TTHMS) above the Maximum Contaminant Level of 80 ug/L (ug/L = ppm = parts per million). NOTE: the contaminant level is calculated based on a running annual average of quarterly samples. See the table below:

Time Period	TTHM (MCL = 80ug/L)	
	Quarterly Average	Running Annual Average
2014 Q4	117.8	
2015 Q1	78.3	100.7
2015 Q2	45.2	81.4
2015 Q3	109.1	87.6
2015 Q4	49.2	70.4
2016 Q1	90.5	73.5
2016 Q2	126.2	93.7

TTHMs are byproducts resulting from the reaction of chlorine, our disinfectant agent, with natural organic and inorganic matter in the water (the agent's target). Chlorine is added to the water to remove any biological contaminants.

On a quarterly basis, we monitor TTHM levels in our distribution system. We use these measurements as guides for making any necessary adjustments to the means and methods of producing drinking water.

What should I do?

This is not an emergency and there is no need to switch to bottled water. If it had been, you would have been notified immediately. However, some people who drink water containing TTHMs and/or HAA5s in excess of the MCL over *many years* could experience liver, kidney, or central nervous system problems and increased risk of cancer. **If you have other health issues concerning the consumption of this water you may wish to consult your doctor.**

More information on the effects of trihalomethanes in drinking water can be found at the US EPA web site: <http://water.epa.gov/drink/contaminants/basicinformation/trihalomethane.cfm>.

If you have tenants, please inform them of this.

With further questions please contact:

John Carnes, SMWC Board Member, (650) 851-1836. Karen Nishimoto, CDPH, (510) 620-3461.